


LONDONDERRY SERIES

LD-__-2014



SCALE: 1/2"=1'-0"

EXAMPLE LD-2014-PSMH-150-208-BLK LD-__-2014-__-__-__-__-__-__ Series Arms Globe Ballast Wattage Voltage Color

ARM		GLOBE	BALLAST	WATTAGE-SOCKET		VOLTAGE		COLOR OF POWDER COAT FINISH	
SC	CENTER		INC	50w	MOGUL	120v	MULTI TAP	(BLK) BLACK	(HG) HAND BRUSHED GREEN
<input type="checkbox"/> 2	<input type="checkbox"/> 2C	<input type="checkbox"/> FROSTED (CLEAR)	<input type="checkbox"/> CFL	<input type="checkbox"/> 70w	<input type="checkbox"/> 250w	<input type="checkbox"/> 208v	<input type="checkbox"/> 120v 240v	<input type="checkbox"/> (BRZ) BRONZE	<input type="checkbox"/> (HR) HAND BRUSHED GRAY
<input type="checkbox"/> 3	<input type="checkbox"/> 3C	<input type="checkbox"/> WHITED (MILKY)	<input type="checkbox"/> HPS	<input type="checkbox"/> 100w		<input type="checkbox"/> 240v	<input type="checkbox"/> 208v 277v	<input type="checkbox"/> (GRN) GREEN	<input type="checkbox"/> CUSTOM _____
<input type="checkbox"/> 4	<input type="checkbox"/> 4C		<input type="checkbox"/> PSMH	<input type="checkbox"/> 150w		<input type="checkbox"/> 277v	PLEASE SPECIFY VOLTAGE		
			<input type="checkbox"/> LED	<input type="checkbox"/> 175w		<input type="checkbox"/> 480v			

ARM SPECIFICATION

ARM
The arm shall be core cast aluminum. Aluminum shall be certified as pure #356 alloy, free of any porosity, foreign materials or cosmetic fillers. Castings shall be uniform wall thickness with no warping or mold shifting. Minimum wall thickness shall be 3/16". Electrical wiring shall run through arm up and out through arm. Electrical components are mounted on globe filler. The globe shall be mounted in the filler with three stainless steel screws.

ELECTRICAL
All electrical components and materials shall be UL-recognized and wired by a certified UL technician. All Niland ballasts are high power factor rated for -30°C/-20°F starting. Medium and Mogul base sockets are 4 KV rated. The electrical assembly is prewired with quick disconnects for servicing. Fixture shall be UL certified for wet locations. Ballast shall be remotely mounted in the base of pole.

MOUNTING
Fixture shall be mounted to 3" O.D. x 10" H. tenon with 8 - 1/8" - 18 x 3/4" S.S. Allen Head Set Screws (8 @ 90°) and (1) 1/2" - 20 x 4" Hex Head Cap Screw.

RELAMPING
The ballast is accessed by loosening 4 stainless steel screws around globe.

FINISH
Fixture finish shall consist of degreasing, phosphate acid etching with 140+ deionized water, rinsed, oven dry off and top coated with a thermoset TGIC super polyester powder coat finish designed not to chalk or fade for many years. All Niland Company powders must pass a minimum 3000-hour salt spray test for corrosion resistance.

CERTIFICATION
The Fixture shall be UL-Listed for wet location use, and all HID listings.

WARRANTY
Niland Company warrants to repair or replace, at our option, any equipment that fails due to defects in material or workmanship within one year from date of shipment. This warranty does not include failures as a result of improper installation, mishandling or misapplication. This guarantee is limited to repair or replacement only and does not include reimbursement for expense of installation, removal of equipment, transportation or any other expenses that may be incurred. Authorization must be obtained from Niland Company in El Paso, Texas before any material is returned.

Catalog Name: LD-__-2014 Date: 02.15.18
Revision History: N/A Revision #: 0

Niland Approval: Luis M. Gomez Customer Approval: _____ Page: 3 of 3

Niland Company

NILAND COMPANY • PH: (915) 779-1405 • FAX: (915) 779-3618 • E-MAIL: INFO@NILANDCO.COM
320 N. Clark El Paso, Tx 79905 • PH: 800-848-9013 • FAX: 888-779-3065 • WEB PAGE: HTTP://www.nilandco.com